

1851 Noriega Street (Existing Pre-School).

Based on the site visit to 1851 Noriega Street (Existing Pre-School) by Captain Patt and FPE Andrawes on 9/20/2018.


Existing Condition:

- 1- The existing preschool area has been approved by building department, planning and fire departments on 2003 per 2001 CBC and CFC.
- 2- There is no change on the occupant load or any modifications to the building.
- 3- The building has a partial sprinkler system and a manual fire alarm.
- 4- Mean of egress provided are through the social hall to public way and the second one through the rear yard (less than 50 feet deep) use as area of refuge.

SFFD Comments:

Conditions for approval.

- 1- Provide an automatic fire alarm system with smoke detection system, the sprinkler system and the fire alarm system shall be monitored.
- 2- Accept the existing approved condition with no change in the occupant load and no increase in the hazard level.
- 3- Provide some steps to the existing rear yard to exit from the rear yard

 Kane

FPE Andrawes

9/25/18

Captain Patt

 Capt.  9/25/18