From: White, Elizabeth (CPC)
Sent: Wednesday, January 16, 2019 8:00 AM
To: Patt, Mike (FIR)
Cc: Poling, Jeanie (CPC)
Subject: RE: Balboa Reservoir EIR

Thank you!

Liz

From: Patt, Mike (FIR)
Sent: Wednesday, January 16, 2019 7:57 AM
To: White, Elizabeth (CPC) <Elizabeth.White@sfgov.org>
Cc: Poling, Jeanie (CPC) <jeanie.poling@sfgov.org>
Subject: RE: Balboa Reservoir EIR

Yes!, (415)558-3215 …. Tell them I referred you to them. The Battalion 9 Chief also is stationed there. Call me if you have any problems.

Thank you,

Captain Michael Patt
698 Second Street, Room 109
San Francisco, CA 94107
Main: 415-558-3300
Direct: 415-558-3364
Fax: 415-558-3323

From: White, Elizabeth (CPC) <elizabeth.white@sfgov.org>
Sent: Tuesday, January 15, 2019 3:51 PM
To: Patt, Mike (FIR) <mike.patt@sfgov.org>
Cc: Poling, Jeanie (CPC) <jeanie.poling@sfgov.org>
Subject: RE: Balboa Reservoir EIR

Hi Captain Patt,

My name is Liz White and I am a colleague of Jeanie Poling at SF Planning. We have some additional questions about the fire station's operations and vehicle maneuvering abilities. I'm wondering if you can put us in contact with someone who works at Fire Station 15?

Thank you,
Liz

Elizabeth White, Senior Environmental Planner
Environmental Planning Division
San Francisco Planning Department
1650 Mission Street, Suite 400 San Francisco, CA 94103
Direct: 415.575.6813 | www.sfplanning.org
San Francisco Property Information Map

From: Poling, Jeanie (CPC)
Sent: Tuesday, January 15, 2019 3:44 PM
To: White, Elizabeth (CPC) <Elizabeth.White@sfgov.org>
Subject: FW: Balboa Reservoir EIR

From: Patt, Mike (FIR)
Sent: Tuesday, January 08, 2019 8:36 AM
To: Poling, Jeanie (CPC) <jeanie.poling@sfgov.org>
Subject: RE: Balboa Reservoir EIR

Hi Jeanie,
Yes, these comments are confirmed.

Thank you,

Captain Michael Patt
698 Second Street, Room 109
San Francisco, CA 94107
Main: 415-558-3300
Direct: 415-558-3364
Fax: 415-558-3323

From: Poling, Jeanie (CPC) <jeanie.poling@sfgov.org>
Sent: Monday, January 07, 2019 2:14 PM
To: Patt, Mike (FIR) <mike.patt@sfgov.org>
Cc: Wietgrefe, Wade (CPC) <wade.wietgrefe@sfgov.org>; White, Elizabeth (CPC) <elizabeth.white@sfgov.org>
Subject: Balboa Reservoir EIR

Hello Captain Patt,

This is to confirm our phone discussion this morning, with your comments on the Balboa Reservoir project and EIR:

- Emergency vehicle access from Fire Station 15 at Ocean Ave/Frida Kahlo Way is already impeded by traffic, and could be made worse by the project. You suggested that a 'keep clear' marking on the pavement could be added but that such markings are often not adhered to. You also suggested a pre-empt button that turns the traffic light red when the station needs to respond to an emergency.
- Aerial trucks require 26-foot-wide street clearance
- AWSS requires new infrastructure (e.g., piping) – this may have been already addressed by the project sponsor

Thanks,
Jeanie Poling
Senior Environmental Planner
San Francisco Planning Department
1650 Mission Street, Suite 400 San Francisco, CA 94103
Direct: 415.575.9072 | www.sfplanning.org
San Francisco Property Information Map